



CITY OF PHILADELPHIA
DEPARTMENT OF LICENSES & INSPECTIONS

Construction Services Division
Municipal Services Building - Concourse Level
1401 John F. Kennedy Boulevard
Philadelphia, Pennsylvania 19102

<p>EZ PERMIT STANDARD ALTERATIONS</p> <p>For alterations to an Existing One Family Dwelling. Deviations from these standards require submission of construction and site plans. Revised 4/19</p>

EZ Alteration Permit Standards

Obtain permits for alterations and renovations of an Existing One Family Dwelling without submitting plans by meeting the Conditions and Limitations below. (Deviations will require submission of plans to the Department.)

Special Flood Hazard Area: If subject property is located within a Special Flood Hazard Area (Floodplain), EZ Alteration Permit **MAY ONLY** be submitted at Permit Services at 1401 JFK Blvd, MSB, Concourse Level. Additional documentation required.

Conditions:

- Work must fully comply with the requirements of the 2015 International Residential Code (IRC) and the 2018 International Existing Building Code (IBC).
- Historically designated buildings require prior approval from the Philadelphia Historical Commission.
- An existing building may not be altered such that the building becomes less safe than its existing condition. Existing levels of protection for the means of egress and fire protection must be maintained.
- Minimum ceiling height of 7 ft. must be maintained for habitable rooms.
- No new floor openings permitted. Stair reconstruction only allowed in existing stair frame openings.
- The work **may not** include the removal, alteration or relocation of any load-bearing components of the structure.
- Basement alteration **may not** include the creation of sleeping units or the alteration of previously approved emergency escape and rescue openings.
- **Separate permits are required for plumbing and electrical work and the installation of heating/cooling appliances.**
- **STRUCTURAL ALTERATION OR REPAIR IS EXPRESSLY PROHIBITED UNDER THIS PERMIT. PROHIBITED STRUCTURAL WORK INCLUDES ANY MODIFICATION TO EXTERIOR WALLS, PARTY WALLS, FLOOR/ROOF FRAMING OR FOUNDATIONS; INCLUDING UNDERPINNING, EXCAVATION, AND REMOVAL OF FOUNDATION SLAB.**

Work May Include:

- Removal of plaster from existing walls and ceilings and removal of non-bearing partitions.
- Installation of gypsum wall board (5/8" Type X required if exterior walls are not masonry.)
- New floors. Sheathing must be lumber sheathing with a minimum 5/8" thickness (joist spacing of 16" on center).
- Installation of partition walls (see Maintaining Minimum Area, Light and Ventilation). New framing must be not less than 2" nominal thickness (1" x 2" furring strips may be used over interior masonry walls).
- Application of stucco or vinyl siding to exterior walls.
- Replacement of doors and windows in existing openings. (Permit not required for this unless Historically Registered.)
- Replacement of roof covering.
- Installation/alteration of ductwork and extension/alteration of fuel gas piping.

Smoke Detectors and Carbon Monoxide Detectors

Hard-wired, interconnected smoke detectors and CO alarms in or just outside each bedroom and smoke detectors in common areas of each floor including basement must be installed where existing plaster or drywall has been removed and/or new drywall is being installed. Combination smoke and CO alarms are recommended.

Water-Resistant Gypsum Backer Board

In all areas subjected to repeated damp conditions and moisture accumulation such as bathtub and shower compartments, water-resistant gypsum backer board complying with ASTM C630 must be used.

Maintaining Minimum Area, Light, and Ventilation

When installing any partitions, minimum room areas, window areas and ventilation, must be maintained as follows:

- Other habitable rooms (except kitchens, baths, halls and closets) must be a minimum of 70 sq. ft. (with a minimum of 7 ft. in one dimension).
- Each of these rooms must have a minimum window area of 8% of the floor area, and the window must have a minimum open area to the outdoors of 4% of the floor area.
- All stairways shall be provided with a means to illuminate the stairs, including any landings. Wall switches shall be located at each floor level.
- Bathrooms must have minimum 3 sq. ft. of window area (1/2 of which shall be openable) **or** mechanical light and ventilation that is exhausted directly to the outside.

AP# _____

Applicant's Signature _____